

BRE Global

UK Approved Body No. 0832

BRE Global Limited Bucknalls Lane, Garston, Watford, Hertfordshire, UK, WD25 9XX Telephone: +44 (0) 333 321 8811 Fax: +44 (0)1923 664603

Email: enquiries@breglobal.com Web: www.breglobal.com

Certificate of UKCA approval constancy of performance 0832-UKCA-CPR-F0947

In compliance with the Construction Product Regulations 2020, UK Statutory Instruments 2020 No.1359 of Ministry of Housing, Communities and Local Government. This certificate applies to the construction product.

AH-03127-BS Conventional Type B Electronic Sounder Beacon

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

Horing Lih Industrial Co Ltd 4F.,No 18, Lane 327 Chung Shan Road Sec. 2, Zhonghe District 235 New Taipei City

Taiwan

Horing Lih Industrial Co Ltd

No 35, Er-Hu Road Hu-Hsi Village Yuan-Shan Hsiang Yilan Hsien, 26445

Taiwan

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-3:2001 + A1:2002 + A2:2006 Sounders

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 28 September 2023 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.

Malligar. Date of First Issue: 28 September 2023

P Halligan, Technical Manager Issue Date: 28 September 2023

On behalf of BRE Global Limited Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com



BRE Global

UK Approved Body No. 0832

BRE Global Limited Bucknalls Lane, Garston, Watford, Hertfordshire, UK, WD25 9XX Telephone: +44 (0) 333 321 8811 Fax: +44 (0)1923 664603

Email: enquiries@breglobal.com Web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F0947

AH-03127-BS Conventional Type B Electronic Sounder Beacon

Notes:

- 1. Meets the requirements of EN 54-3 at the following tones:
 - 1 Alternating Tones 800/970Hz at 2Hz
 - 2 Sweeping 800/970Hz at 7Hz
- 2. The beacon functionality is not included within the scope of approval.

Bases:

AH-03127MB

P Halligan, Technical Manager

Malligan. Date of First Issue: 28 September 2023

On behalf of BRE Global Limited Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com

Issue Date:

28 September 2023

BF2132 Rev.0.1 Page 2 of 2 © BRE Global Limited, 2021