# LPCB®

www.redbooklive.com

## **Certificate of Product Approval**

Certificate Number: 506b

Issue: 12

PКЕ

### **Horing LIH Industrial Co Ltd**

No. 35, Er-Hu Road Hu-Hsi Village Yuan-Shan Hsiang Yilan Hsien, 26445 Taiwan

is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

### **Products**

Smoke Detectors Q05-2 Q05-3 Q05-4 (refer to Appendix for details)

#### **Standards**

EN 54-5:2017 + A1:2018 EN 54-7:2018 CEA 4021:2003

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

| P. Walligar.              | P Halligan | 28 September 2023 | 23 May 2005         |  |
|---------------------------|------------|-------------------|---------------------|--|
| Signed for BRE Global Ltd | Verifier   | Date of Issue     | Date of First Issue |  |



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit <u>www.redbooklive.com/terms</u>). To check the validity of this certificate and appendix please visit <u>www.redbooklive.com/check</u>, scan the QR tag or contact us. BRE Global Ltd, Watford, WD25 9XX T: +44 (0)333 321 8811 E: <u>enquiries@breglobal.com</u>

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



# LPCB®

## Appendix to Certificate No: 506b

### Issue: 12

### Horing LIH Industrial Co Ltd

| Certified<br>Product | Description   | LPCB Ref.No. |
|----------------------|---|--------------|
| Q05-2                | Conventional 2-Wire Optical Smoke and Category A2 Heat Detector<br>(AHMB-061-2 and AHMB-071-2 Bases)                | 506b/04      |
| Q05-3                | Conventional 3-Wire Optical Smoke and Category A2 Heat Detector with Remote LED (AHMB-061-3 and AHMB-071-3 Bases)   | 506b/05      |
| Q05-4                | Conventional 4-Wire Optical Smoke and Category A2 Heat Detector with Relay Output (AHMB-061-4 and AHMB-071-4 Bases) | 506b/06      |

#### Bases

| AHMB-061-2 | Standard Base |
|------------|---------------|
| AHMB-061-3 | Standard Base |
| AHMB-061-4 | Standard Base |
| AHMB-071-2 | Base Unit     |
| AHMB-071-3 | Base Unit     |
| AHMB-071-4 | Base Unit     |
|            |               |

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

| P. Malligar.   | P Halligan  | 28 September 2023 | 23 May 2005         |
|--|---|-------------------|---------------------|
| Signed for BRE Global Ltd  | Verifier  | Date of Issue     | Date of First Issue |
| UKAS<br>PRODUCT<br>CERTIFICATION<br>UKAS<br>PRODUCT<br>CERTIFICATION<br>0007 | This certificate and appendix remains the property of BRE Global Ltd. and is<br>subject to terms and conditions (for details visit <u>www.redbooklive.com/tern</u><br>To check the validity of this certificate and appendix please visit<br><u>www.redbooklive.com/check</u> , scan the QR tag or contact us.<br>BRE Global Ltd, Watford, WD25 9XX<br>T: +44 (0)333 321 8811 E: <u>enquiries@breglobal.com</u><br>LPCB is a Registered Trademark of the Building Research Establishment Ltd. |                   |                     |

80018