

## Kitemark™ Certificate

This is to certify that:

Horing Lih Industrial Co., Ltd.  
I-Lan Branch (Yuan-shan plant)  
No. 35, Er-Hu Road  
Hu-Hsi Village  
Yuan-Shan Hsiang  
Yilan Hsien  
26445  
Taiwan

Holds Certificate Number:

KM 632125

In respect of:

**BS EN 54-2 & BS EN 54-4**

**Fire detection and fire alarm systems - Control and indicating equipment & Power supply equipment**

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.



---

Shahm Barhom, Group Product Certification Director

For and on behalf of BSI:

First Issued: 2025-11-14

Effective Date: 2025-11-14

Latest Issue: 2025-11-14

Expiry Date: 2028-11-13

Page: 1 of 2



This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

# Kitemark™ Certificate

No. KM 632125

**BS EN 54 Part 2:1997 + A1:2006 - Fire detection and fire alarm systems: Control and indicating Equipment and BS EN 54 Part 4:1998 + A1:2002 + A2:2006 - Fire detection and fire alarm systems: Power supply equipment**

## **Model Reference      Type**

Vivid 32              1 to 32 Zone conventional CIE – 4.5Amp PSE in 350 x 350 x 95 mm Housing

Vivid 32              1 to 32 Zone conventional CIE – 4.5Amp PSE in 350 x 400 x130 mm Housing

Incorporating the following software versions:

32 Zone configured display board U1 – V3201A05

32 Zone configured display board U34 – V3201B06

Single zone configured display board U1 – V3201A05

Single zone configured display board U34 – V3201B06

Certified for use with Yuasa NP7-12FR and NP4-12 batteries.

## **Options with requirements**

Certified with the following options with requirements from BS EN 54 Part 2:1997:

### **Clause Description**

7.8              Output to fire alarm devices

First Issued: 2025-11-14

Latest Issue: 2025-11-14

Effective Date: 2025-11-14

Expiry Date: 2028-11-13

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at Seventh and Eighth Floors, The Acre, 90 Long Acre, London, WC2E 9RA, UK.  
A member of BSI Group of Companies.