

## BRE Global

### UK Approved Body No. 0832

BRE Global Limited  
Bucknalls Lane, Garston, Watford,  
Hertfordshire, UK, WD25 9XX  
Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
Web: [www.breglobal.com](http://www.breglobal.com)

## Certificate of UKCA approval constancy of performance 0832-UKCA-CPR-F0939

In compliance with the Construction Product Regulations 2020, UK Statutory Instruments 2020 No.1359 of Ministry of Housing, Communities and Local Government. This certificate applies to the construction product.

### Q05-4 Conventional 4 Wire Optical Smoke Detector and Category A2 Heat Detector with Relay Output

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

Horing Lih Industrial Co Ltd  
No 35, Er-Hu Road  
Hu-Hsi Village  
Yuan-Shan Hsiang  
Yilan Hsien, 26445  
Taiwan

Horing Lih Industrial Co Ltd  
No 35, Er-Hu Road  
Hu-Hsi Village  
Yuan-Shan Hsiang  
Yilan Hsien, 26445  
Taiwan

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

### EN 54-5:2017 + A1:2018 Heat Detectors – Point Detectors EN 54-7:2018 Smoke Detectors – Point Detectors

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### the constancy of performance of the construction product.



This certificate was first issued on 28 September 2023 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.

Z Major, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 28 September 2023

Issue Date: 29 April 2026

Issue Number: 02

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

**BRE Global**

**UK Approved Body No. 0832**

BRE Global Limited  
Bucknalls Lane, Garston, Watford,  
Hertfordshire, UK, WD25 9XX  
Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
Web: [www.breglobal.com](http://www.breglobal.com)

**APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F0939**

**Q05-4 Conventional 4 Wire Optical Smoke Detector and Category A2 Heat Detector with Relay Output**

**Bases:**

AHMB-061-4 Standard base  
AHMB-071-4 Base unit



Z Major, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 28 September 2023

Issue Date: 29 April 2026

Issue Number: 02

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com)