

BRE Global

Notified Body No. 0832
BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

Certificate of constancy of performance

0832-CPR-F2163

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

IR-0714-2 Infrared Single Flame Detector

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

Horing Lih Industrial Co Ltd
No 35, Er-Hu Road
Hu-Hsi Village, Yuan-Shan Hsiang
Yilan Hsien 264
Taiwan
ROC

and produced in the manufacturing plant(s):

Horing Lih Industrial Co Ltd
No 35, Er-Hu Road
Hu-Hsi Village, Yuan-Shan Hsiang
Yilan Hsien 264
Taiwan
ROC

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-10:2002 + A1:2005 Flame Detectors

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 06 June 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Manager,

On behalf of BRE Global Limited

Date of First Issue: 06 June 2019

Date of Issue: 06 June 2019

Issue number 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com.



BRE Global Limited

Bucknalls Lane,
Garston, Watford,
Hertfordshire, UK,
WD25 9XX

Notified Body No. 0832

Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-CPR-F2163

IR-0714-2 Infrared Single Flame Detector

Note:

Meets EN 54-10:2002 at Class 2 and 3 Sensitivity

Base:

AHMB-071 Mounting base

P Halligan, Certification Manager,
On behalf of BRE Global Limited

Date of First Issue: 06 June 2019

Date of Issue: 06 June 2019

Issue number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com.